

Certificate of Conformity

By the product certificate number

No. 2622/0478-C-E1-CER

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark: **victron energy**
BLUE POWER

Contract number: **802190**

It is certified that the product:

Type of product: **Inverter/Charger with UPS functionality**

Models:		MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:	Rated Power	8.0 kVA / 6.4 kW	10.0 kVA / 8 kW	15.0 kVA / 12.0 kW
	Rated Voltage		AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V	
	Rated Frequency		50 Hz	
	Firmware version	2621502	2627502	2619502
	Number of phases		Single Phase (L/N/PE)	
	Isolation transformer		Yes	

Is in compliance with the standard:

- **Technical Prescription C10/11 of Synergrid. Edition 2.2 (15.03.2021) (1)**

(1) Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate cancels and supersedes certificate no. 2622/0478-C-CER.

This certificate is first issued on 29th January 2024. This certificate is valid until the 5th July 2028.

Madrid, 29th January 2024

Daniel Arranz Muñiz
Certification Manager



S SGS Tecnos, S.A.U. C/ Trespaderna, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions.
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).
This document cannot be reproduced partially



No. 2622/0478-C-E1-CER

Page 1 of 1